OWNER'S MANUAL

°STELPRO

NON-PROGRAMMABLE ELECTRONIC THERMOSTAT FOR FAN HEATERS

> ST252NPFF ST402NPFF

1-844-STELPRO WWW.STELPRO.COM

IMPORTANT INSTRUCTIONS

THE THERMOSTAT MUST BE INSTALLED BY A CERTIFIED ELECTRICIAN.

Connect the thermostat to a 120 to 240 VAC power source ONLY and comply with load limits.

WARNING – HIGH VOLTAGE Turn off the power supply before installation and main-tenance. Leave at least 12 in. (30 cm) clearance around the thermostat to ensure that it is properly vented.

SAVE THESE INSTRUCTIONS

TECHNICAL SPECIFICATIONS

VOLTAGE AND LOAD				
PRODUCT CODE	SUPPLY VOLTAGE	LOAD AT 120 V	LOAD AT 240 V	
	VOLTS	WATTS	WATTS	
ST252NPFF	120-240	150-1250	300-2500	
ST402NPFF		150-2000	300-4000	
Load control type	ontrol type Resistive			
Frequency	60 Hz	60 Hz		
Storage temperature -40°C to 50°C (-40°F		°C (-40°F to 122°F)		
Operating tempera		-20°C to 50°C (-4°F to 122°F). LC display less effective below 0°C (32°F)		
Humidity	5% to 98%	5% to 98% without condensation		
Action	Type 1.Y	Type 1.Y		
Pollution degree	2	2		
Software	re Class A			
Rated impulse voltage Catego		II overvoltage (1500 V)		
Independently mounted control for surface mounting				
Thermistor used as a sensor, carries no load current				
Overload protection device external to the control: circuit breaker (refer to local electrical code)				

°STELPRO LIMITED WARRANTY

Limited three-year warranty. See details on www.stelpro.com.

BEFORE YOU GET STARTED


- The box contains one (1) thermostat with mounting plate, two (2) mounting screws, three (3) twist-on wire connectors and one (1) owner's manual.
- To install this thermostat, you will need a #2 Phillips screwdriver.
- Install your thermostat about 5 ft (1.5 m) from the floor on an inside wall facing the heating system.

INSTALLATION

ATTACH THE MOUNTING PLATE

WARNING Turn off the power supply.


- 1. Loosen the screw [A] at the top of the thermostat [B] without removing it.
- 2. Separate the mounting plate [C] from the thermostat. Pull the top of the plate and rotate it as shown.
- 3. Take the power wires [D] out of the junction box [E] and run them through the large opening in the center of the mounting plate [F].
- 4. Using the two (2) mounting screws provided [G], attach the thermostat mounting plate to the junction box [E]. The plate can be centered on the junction box or shifted to the left or right.



CONNECT THE POWER **SUPPLY WIRES**

1. Complete the thermostat's electrical connection according to the diagram below. Tighten the wires securely in the supplied wire connectors.

2. Push the wires and connectors into the electrical box.



The diagram shows a 240 V power supply.

WARNING Incorrectly connected electrical

wires could result in a fire hazard.


EN2

NOTE: If the electrical wires are aluminum, use CO/ALR connectors instead (not supplied)

INSTALLATION – CONT'D

3 ATTACH THE THERMOSTAT


- **1.** Using the alignment guide, hook the bottom **[A]** of the thermostat into the bottom of the plate. Be sure not to jam the wires between the thermostat and mounting plate.
- 2. Rotate the thermostat upwards [B] and attach it on the top hook of the mounting plate.
- 3. Tighten the screw at the top of the thermostat [C] to hold it in place securely.
- 4. Restore the power at the circuit breaker.



NOTE: If you need to remove the thermostat, follow step 1 in section 1, then use a straight screwdriver to unhook it from the top of the mounting plate.

INTERFACE

This is a non-programmable thermostat. The temperature setpoint remains constant unless you change it.



*Displays only when using the advanced menus.

Touch the keypad once to activate the backlight, then you can make changes.

INITIAL SETTINGS

To begin with, follow the on-screen instructions to adjust your thermostat's settings. Press (or) to change your selection and () to confirm.

- 1. Temperature format: °C / °F (Celsius / Fahrenheit)
- **2.** ECO mode setpoint temperature (5 °C to 30 °C / 41 °F to 86 °F). By default, the ECO mode setpoint is 17 °C / 63 °F.

Your heating needs may vary according to the season and even the time of day. To meet your needs, this thermostat is equipped with two distinct modes: ECO and COMFORT. You can switch from one mode to another by simply pressing (). ECO mode saves you money by providing a more energy-efficient setpoint temperature when you're sleeping or away from home.

3. Lobby mode: Std / Lby (Standard room / Lobby).

In Lobby mode, the thermostat automatically provides 100% heating for five minutes as soon as a sudden drop in temperature is detected. This mode can be useful for heaters located near an entrance. When this mode is activated, the 🕹 icon flashes.

YOUR THERMOSTAT IS NOW READY TO USE!

FEATURES

KEY FEATURES

- **1.** Press $\langle\!\langle$ or $\rangle\!\rangle$ once to lower or raise the setpoint temperature by 0.5 °C / 1 °F. The setpoint temperature will remain at this value until it is changed. Note: If you change the setpoint temperature while in ECO mode, the thermostat will switch to COMFORT mode.
- 2. Press
 once to switch from ECO mode to COMFORT mode and vice versa.
- 3. Press (and) simultaneously to activate BOOST mode . Then, press (or) to select BOOST mode duration (10, 20, 30, 40, 40, 50 or 60 minutes). The thermostat will then heat at 100% for the time specified.

ADVANCED MENU ACCESS AND USE

- **1.** Press and hold (1) for three (3) seconds to access the thermostat's advanced menus.
- **2.** Press $\langle \langle \text{ or } \rangle \rangle$ to change your selection.
- **3.** Press D to confirm your selection and proceed to the next menu.
- **4.** Press and hold (1) for three (3) seconds to exit the advanced menus.

ADVANCED MENUS LIST

- Menu 10 Temperature format: °C / °F (Celsius / Fahrenheit
- Menu 20 ECO mode setpoint temperature (5 °C to 30 °C / 41 °F to 86 °F). By default, the ECO mode setpoint is 17 °C / 63 °F.
- Menu 30 Lobby mode: Std / Lby (Standard room / Lobby)
- Menu 40 Keypad lock: ON / OFF (Lock / Unlock keypad)
- **dEF** Reset thermostat to default values: N / Y (No / Yes)